

## SECTION 10 14 00 – Signage

Document revision history: 08/2019 – Original Publication

Date	Section	Description of Change
3/29/24	All Sections	Edited for brevity and including cross references to relevant appendices.
11/20/25	2.1 Materials	Move Building Directories information to Interior Signage Appendix and reference Campus Outdoor Sign Plan for all Exterior Signage.

### PART 1 – GENERAL

#### 1.1 Summary

- Complete room number assignment is required at 100% DD for approval and/or revision by UO.
- These room numbers are then to be finalized with only minor revisions during the CD phase as MEP schedules will use these designations. See Room Numbering Guide Appendix.
- Interior room signage on large projects is to be provided and installed by the GC.
- Design of signage is either by the design team or by design-build with the GC. See Interior Signage Appendix for complete specification and design guidelines.
- On small to medium remodel projects, only interior signage can be OFOI (Requires coordination with Owner's Rep).
- Egress routes shall be reviewed and approved by UO EH&S and/or the UO Fire Marshal's Office.
- Map media shall be designed and installed for easy future revision.

#### 1.2 Submittals

- Modifiable electronic files (AutoCAD) for all Egress Route maps shall be provided with record documents for future use.

#### 1.3 Qualifications

- Not applicable.

### PART 2 – PRODUCTS

#### 2.1 Materials

- Exterior Signage
  - See Campus Outdoor Sign Plan.
- Interior signage
  - See Interior Signage Appendix.

### PART 3 – EXECUTION

#### 3.1 Installation

- Not applicable.

#### 3.2 Interface with other products

- Provide permanent interior and exterior signage at all utilities, shut-offs, equipment, etc. locations; including ceiling locations.

**SECTION 10 44 00 – Fire Protection Specialties**

Document revision history: 08/2019 – Original Publication

Date	Section	Description of Change

**PART 1 – GENERAL****1.1 Summary**

- a. Not applicable.

**1.2 Submittals**

- a. Not applicable.

**1.3 Qualifications**

- a. Not applicable.

**PART 2 – PRODUCTS****2.1 Materials**

- a. Portable fire extinguisher cabinets; and portable fire extinguishers in UO owned, rented or leased buildings shall be as follows:
  - General: Fire extinguisher class, type, size, distribution and mounting locations shall be detailed on the layout of the building or area thereof, and shall be included on the building plans for review and approval by the UO Fire Marshal's Office (UOFMO).
    - i. Extinguishers in public areas, recreation areas, and residence halls are to be housed in cabinets.
    - ii. Recessed extinguisher cabinets are allowed in corridors and areas where ADA compliance requires a recessed cabinet only and only with prior Owner approval.
  - Conspicuous Location: Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless UOFMO staff determines that the hazard posed indicates the need for placement away from normal paths of travel.
  - Unobstructed and Unobscured: Portable fire extinguishers shall not be obstructed or obscured from view. In rooms or areas in which visual obstruction cannot be completely avoided, approved means shall be provided to indicate the locations of extinguishers. Under no circumstances shall fire extinguisher locations to be designed to be placed on the floor, behind equipment or storage, or inside of a piece of casework or cabinet.
  - Hangers and Brackets: Hand-held portable fire extinguishers, not housed in cabinets, shall be installed on the hangers or brackets supplied by their manufacturers.
    - i. Slide type extinguisher hangers only that are Amrex compatible.
    - ii. No pin hangers.
  - Cabinet Specifications:
    - i. Trim and Door Material: Cabinets trim and doors shall be made out of "Stainless Steel" material.
    - ii. Trim Projection: Approved cabinets may be of the recessed, semi-recessed, or surface mount types.
    - iii. Type of Lock: Cabinets used to house portable fire extinguishers shall not be locked; therefore, they shall not have a locking mechanism.
  - Exceptions: (The use of the exceptions listed below shall be approved by the UOFMO.)

- i. Where portable fire extinguishers subject to malicious use or damage are provided with a means of ready access.
  - ii. In Group I-3 occupancies and in mental health areas in Group I-2 occupancies, access to portable fire extinguishers shall be permitted to be locked or to be located in staff locations provided the staff has keys.
- Door Style and Door Glazing:
  - i. Cabinet doors must have a pull handle, and shall have “Full Panel View” style glazing.
  - ii. Type of Glazing: Cabinet door glazing must be “Tempered Safety Glass.”
- Extinguisher Types:
  - i. 2A10BC for all applications other than kitchen spaces.
  - ii. K for kitchen applications with either grease or fryers.
  - iii. 20BC for all other kitchen applications.

## **PART 3 – EXECUTION**

### **3.1 Installation**

- a. Extinguisher Installation:
  - Whether installed on hangers or brackets, or housed in cabinets, the installation of portable fire extinguishers shall be as recommended in manufacturer’s instructions, and in accordance with the following:
    - i. Extinguishers weighing 40 pounds or less.  
Portable fire extinguishers having a gross weight not exceeding 40 pounds (18 kg) shall be installed so that their tops are not more than 5 feet above the floor.
    - ii. Extinguishers weighing more than 40 pounds.  
Hand-held portable fire extinguishers having a gross weight exceeding 40 pounds (18 kg) shall be installed so that their tops are not more than 3.5 feet above the floor.
    - iii. Floor clearance.  
The clearance between the floor and the bottom of installed hand-held portable fire extinguishers shall not be less than 4 inches.

### **3.2 Interface with other products**

- a. Not applicable.

### **3.3 Testing**

- a. Compliance inspection required at least three business days prior to the desired date of the building opening to the public. Contact University Fire Marshal’s Office staff at 541-346-2958 or 541-346-3270.

### **3.4 Training**

- a. Not applicable.

**SECTION 10 50 00 – Storage Specialties**

Document revision history: 08/2019 – Original Publication

Date	Section	Description of Change

**PART 1 – GENERAL****1.1 Summary**

- a. Not applicable.

**1.2 Submittals**

- a. Not applicable.

**1.3 Qualifications**

- a. Not applicable.

**PART 2 – PRODUCTS****2.1 Materials**

- a. All shelving standards and brackets are to be double-slotted.
- b. Standards to be installed at a maximum of every 16 inches on-center.

**PART 3 – EXECUTION****3.1 Installation**

- a. All shelving is to be secured to building structure to prevent tipping; wall, office system, etc.

**3.2 Interface with other products**

- a. Not applicable.

**3.3 Testing**

- a. Not applicable.

**3.4 Training**

- a. Not applicable.