

Thermal Systems Taskforce Campus Public Forum

Brian Fox, *AVP Budget, Financial Analysis and Data Analytics*

Steve Mital, *Director of Energy and Sustainability*

Winter 2024 Project Update



Presentation Agenda

- Overview of Process and Timeline
- Overview of Options
- *NEW Climate Protection Plan Update*
- *NEW Project Option Costs, Campus Impacts, and Estimated Emissions Reductions*
- *NEW Initial/Draft Taskforce Recommendations & Discussion*
- Facilitated Q&A
- Table Discussions



Thermal Taskforce

Work to Date &
Process Forward



Thermal Systems Taskforce

- Taskforce Membership: Board members, faculty, students, staff
- Taskforce Charter:
 - **REVIEW technical reports**, energy markets/regulations and complete due diligence on a potential thermal system transition
 - **ENGAGE the campus community** on available options and incorporate feedback
 - **RECOMMEND to the president** a long-term plan to support the recapitalization of the UO's campus heating infrastructure, balancing the following goals:
 - reduction of greenhouse gas emissions,
 - resiliency of campus heat production to energy markets and natural hazards,
 - limited disruption to student's campus experience, and
 - appropriate fiscal stewardship.

Thermal Systems Taskforce Timeline

Fall 2022

- Taskforce review phase I heating study, UO emissions, set workplan
- Commission phase II technical analysis

Winter 2023

- Taskforce review existing infrastructure, regulatory and market issues

Spring 2023

- Initial Community outreach and campus forums
- Taskforce reviews campus feedback

Summer 2023

- Analyze input costs, develop carbon intensity factors, and existing regulatory environment
- Work closely with consulting engineers to develop life cycle cost analysis (LCCA)

Fall 2023

- Begin Fall Term engagement with campus community
- Complete emissions reduction estimates, financial analysis and due diligence process

Winter 2024

- Receive Concept Design for water-based distribution system (1/5/2024)
- Review engineering and LCCA findings, develop initial recommendation
- Present findings and initial recommendation to campus community
- Review campus input and finalize recommendation(s) to President
- Submit report to President and present to Board of Trustees

An aerial photograph of a university campus. The image is partially obscured by a dark green rectangular overlay on the left side, which contains white text. The campus features various buildings, a large circular arena, and several sports fields. The green overlay covers the top-left and middle-left portions of the image.

Regulatory Updates Climate Protection Program




Oregon's Climate Protection Program

- Formally adopted in 2021
- Required natural gas providers to reduce emissions over the next 30 years
 - 50% by 2035
 - 90% by 2050
- Was successfully challenged in Oregon State Court of Appeals in December 2023.
 - The court decided that DEQ did not fully comply with notice requirements during the rulemaking process, thereby invalidating the final rules and the program.
- On January 22, 2024 DEQ announced it would not appeal.
 - DEQ plans to resolve the issue by re-launching the rule-making process.
 - Expected to take 12 months

Oregon's Climate Protection Program

- UO conducted analysis of CPP cost, technical feasibility, and impact on emissions reductions.
- UO removed CPP from consideration until its legality is resolved.
- UO established “Business As Usual” (current operations) as the baseline to which emissions reduction options are compared.
- UO will continue to monitor CPP and all federal, state, and local regulatory and policy developments.



Heating System Options

Existing System Structure
Options and Impacts



UO's Existing Steam District Heating System



UO District Heating System - BAU



Central
Boilers




Steam
Tunnels



Building
Heat Systems




Business as Usual (BAU) Estimated Cost & Emissions




Thermal System Options Analyzed

(1): SYSTEMS AS USUAL




(3): HEAT RECOVERY CHILLER (HRC)



(2): ELECTRODE BOILER



(4): GEO-EXCHANGE + HRC



Overview of Options 2A and 2B – Electrode Boilers

Overview:

- Use electricity to make steam in place of existing natural gas boilers.
- Pairs with existing steam heat distribution system
- Estimated annual emissions reduction from BAU in 2028: 2A 78% | 2B 45%
- Estimated cumulative emissions reduction from BAU in 2028: 2A 53% | 2B 35%

Pros:

- Fastest and simplest (non-disruptive) change. Integrate directly with existing system.
- 2A electrifies 95% of heating. Requires electrical infrastructure improvements/investments.
- 2B electrifies 54% of heating. Fits within existing electrical and space constraints.
- Immediate emissions reductions upon implementation

Cons:

- Older/less efficient technology and potential stranded asset (2A)
- 2A boiler increases utility cost by \$8.1 million per year in 2028
- 2B boiler increases utility cost by \$4.4 million per year in 2028

| Scenario | Capital Cost (2023 dollars) |
|---|--------------------------------|
| 18 MW Electrode Steam Boiler (Option 2A) | \$29.7M |
| 8 MW Electrode Steam Boiler (Option 2B) | \$14.9M |



Overview of Option 3 – Heat Pump Chiller

Overview:


- Captures heat that would've been vented to atmosphere via cooling towers and uses it to meet heating needs
- Estimated annual emissions reduction from BAU in 2028 / 2043: 26% / 56%
- Estimated cumulative emissions reduction from BAU in 2028 / 2043: 10% / 40%

Pros:

- Reduces emissions by electrifying 58% of heating
- Extremely efficient use of energy and reduced maintenance reduces annual operating cost below BAU
- Estimated to receive \$3.4M from IRA

Cons:


- Requires replacement of steam distribution system with hot water system and building system upgrades
- Emissions reductions phased in gradually over 12+ years while system is built
- Is less effective meeting wintertime heating needs



Overview of Option 4 – Geo-Exchange

Overview:

- Adds to HRC (Option 3)
- Requires ~1,400 boreholes (600 ft deep)
- Estimated annual emissions reduction from BAU in 2028 / 2043: 29% / 76%
- Estimated cumulative emissions reduction from BAU in 2028 / 2043: 11% / 54%




Pros:

- Reduces emissions by electrifying 86% of heating
- Extremely efficient use of energy and reduced maintenance costs means annual operating cost below BAU (after debt service)
- Estimated to receive \$27.2M from IRA and as much as \$138.9

Cons:

- Requires replacement of steam distribution system with hot water system and building system upgrades
- Emissions reductions phased in gradually over 12+ years while system is built

Options 3 / 4 Require Steam to Hot Water Conversion




Hot Water Distribution System

- Distribution system transports hot water from the plant to the buildings for heating and back

| Phase | 2023 Cost | Notes |
|--------------|----------------------|---|
| Initial | \$43,400,000 | <p>Costs shown here are the estimated costs in 2023 dollars.</p> <p>The amounts include direct construction, design, and associated project costs.</p> <p>The costs shown do not include financing costs or estimated escalation to year of construction.</p> |
| 1 | \$60,600,000 | |
| 2 | \$57,200,000 | |
| 3 | \$21,600,000 | |
| 4 | \$40,400,000 | |
| 5 | \$31,700,000 | |
| 6 | \$31,100,000 | |
| Total | \$286,000,000 | |

- Only needed for options 3 and 4. System Design:
 - Direct bury
 - Loop design to have multiple pathways into buildings for increased resilience
- Significant campus disruption anticipated with potential impact to historic trees

Options 3 / 4 Require Building Hot Water Conversions



Building Conversions

- All buildings currently receive steam for heating and need to be converted from using steam from the central plant to hot water. Only applies to options 3 and 4
- Buildings divided between full steam distribution, partial steam distribution, full hydronics, and hot water temperature
- Included cost for displaced use (21 buildings requiring staff/program relocation, \$55M)
- Included cost for rental boiler (2 small boilers throughout transition)

| Phase | 2023 Cost | Notes |
|--------------|----------------------|---|
| 1 | \$72,600,000 | Costs shown here are the estimated costs in 2023 dollars. The amounts include direct construction, design, and associated project costs. |
| 2 | \$45,400,000 | |
| 3 | \$39,500,000 | |
| 4 | \$67,000,000 | |
| 5 | \$44,600,000 | |
| 6 | \$27,800,000 | |
| Total | \$296,900,000 | The amounts do not include financing costs or estimated escalation to year of construction. |

Total Construction Costs

| Estimated Project Costs (2023\$) | Option 2a (18MW Ele Blr) | Option 2b (8MW Ele Blr) | Option 3 (HPC) | Option 4 (Geo) |
|---|-----------------------------|----------------------------|----------------------|--------------------------------|
| Electrode Boiler and Electrical Modifications | \$29,700,000 | \$14,900,000 | \$0 | \$0 |
| Hot Water Distribution | \$0 | \$0 | \$286,000,000 | \$286,000,000 |
| Hot Water Building Conversions | \$0 | \$0 | \$296,900,000 | \$296,900,000 |
| Hot Water Plant Modifications | \$0 | \$0 | \$93,500,000 | \$93,500,000 |
| Geoexchange System | \$0 | \$0 | \$0 | \$66,400,000 |
| Potential IRA Credits | \$0 | \$0 | (\$3,400,000) | (\$27.6M) - (\$138.9M) |
| Total Cost without IRA | \$29,700,000 | \$14,900,000 | \$673,000,000 | \$742,800,000 |
| Total Cost with IRA Credits | \$29,700,000 | \$14,900,000 | \$669,600,000 | (\$715.2M) - (\$603.9M) |


- Option 3 / 4 include:
 - Hot water distribution costs
 - Building conversation costs
 - Heating system (HRC and HRC + Geo-Exchange) costs
 - IRA credits
- Option 2A / 2B include:
 - Electrode steam boiler costs
 - Electrical and other infrastructure costs




Estimated Costs & Emissions Reductions




Life Cycle Cost Results – Annual Operating Costs




Life Cycle Cost Results – Annual Operating Costs




Life Cycle Cost Results – Annual Operating Costs



Life Cycle Cost Results – Annual Operating Costs




Life Cycle Cost Results – Annual Operating Costs




Life Cycle Cost Results – Cost Comparisons


BAU Annual Cost Components (Present Value)




Option 2a Annual Cost Components (Present Value)




Option 2b Annual Cost Components (Present Value)




Option 3 Annual Cost Components (Present Value)




Option 4 Annual Cost Components (Present Value)



Life Cycle Cost Results – Cost Comparisons



Life Cycle Cost Results – Emissions Reductions



| Annual Emissions Reduction (vs BAU) | Option 2a (18MW Ele Blr) | Option 2b (8MW Ele Blr) | Option 3 (HPC) | Option 4 (Geo) |
|-------------------------------------|--------------------------|-------------------------|----------------|----------------|
| 2028 | 78% | 45% | 26% | 29% |
| 2033 | 77% | 44% | 41% | 56% |
| 2043 | 76% | 42% | 56% | 76% |
| 2053 | 75% | 42% | 58% | 75% |
| 2083 | 75% | 42% | 58% | 75% |

| Cumulative Emissions Reduction (vs BAU) | Option 2a (18MW Ele Blr) | Option 2b (8MW Ele Blr) | Option 3 (HPC) | Option 4 (Geo) |
|---|--------------------------|-------------------------|----------------|----------------|
| 2025 – 2028 | 53% | 35% | 10% | 11% |
| 2025 – 2033 | 67% | 40% | 25% | 32% |
| 2025 – 2043 | 72% | 41% | 40% | 54% |
| 2025 – 2053 | 73% | 42% | 46% | 61% |
| 2025 – 2085 | 74% | 42% | 52% | 69% |

This analysis utilizes the prior 10-year average GHG intensity for EWEB provided electricity, as calculated by Oregon DEQ. This chart does not reflect that during early years of the analysis peaker plants may be used to fulfill new electrical load that generate higher GHG emissions. It also does not incorporate EWEB’s 95% decarbonization plan and additional planned decarbonization of the northwest grid.

Total Capital and Operating Costs (NPV) and Cumulative Emissions Reductions

| | BAU | BAU (with CPP) | Option 2a (18MW) | Option 2b (8MW) | Option 3 | Option 4 |
|---|-----------------|-------------------|---------------------|--------------------|-----------------|-----------------|
| Capital Construction Costs (Present Value, Financed) | \$105,000,000 | \$105,000,000 | \$179,300,000 | \$147,300,000 | \$1,096,800,000 | \$1,174,100,000 |
| IRA Benefit (Present Value) | \$0 | \$0 | \$0 | \$0 | -\$3,400,000 | -\$27,200,000 |
| Marginal Cost vs BAU | - | \$0 | \$74,300,000 | \$42,300,000 | \$991,800,000 | \$1,069,100,000 |
| Operating and Maintenance Costs (Present Value, Cumulative) | \$1,657,000,000 | \$1,699,600,000 | \$2,020,800,000 | \$1,864,500,000 | \$1,599,700,000 | \$1,596,900,000 |
| Marginal Cost vs BAU | - | \$42,600,000 | \$363,800,000 | \$207,500,000 | -\$57,300,000 | -\$60,100,000 |
| Total Option Cost (Present Value, Financed) | \$1,762,000,000 | \$1,804,600,000 | \$2,200,100,000 | \$2,011,800,000 | \$2,696,500,000 | \$2,771,000,000 |
| Total Marginal Cost vs BAU | - | \$42,600,000 | \$438,100,000 | \$249,800,000 | \$934,500,000 | \$1,009,000,000 |
| 2038 Annual Operating + Maint + Debt Service (Present Value) | \$27,500,000 | \$28,200,000 | \$35,600,000 | \$31,800,000 | \$66,300,000 | \$69,900,000 |
| 2085 Annual Operating + Maint + Debt Service (Present Value) | \$29,900,000 | \$30,600,000 | \$35,600,000 | \$33,200,000 | \$28,000,000 | \$27,700,000 |
| Total Cumulative Emissions (2023-2085, MTCO2e) | 1,735,000 | 822,000 | 486,000 | 1,027,000 | 854,000 | 578,000 |
| Cumulative Emissions Reduction (2023-2085, MTCO2e) | - | (913,000) | (1,249,000) | (708,000) | (881,000) | (1,157,000) |
| Cumulative Emissions Reduction (%) (vs BAU) | - | 53% | 72% | 41% | 51% | 67% |
| ~Cost per MTCO2e Reduction (Present Value) | - | \$47 | \$351 | \$353 | \$1,061 | \$872 |




University Finances



Existing University Debt Service & Lease Payments

Debt Service and Lease Payments




*OUS-issued debt includes SELP but is net of expected SELP appropriations and Build America Bond subsidies.

**Excludes right-of-use payments and subscription-based IT arrangements.

The current principal balance of outstanding debt, including capital leases, is approximately \$846 million

This is a decrease of approximately \$32 million from the same date a year ago

University Debt Burden Ratio



Major Revenue Sources & Academic Expenditures

| School and College Education & General Budgets | FY 2023 |
|--|---------|
| College of Design | \$26M |
| College of Arts & Sciences | \$153M |
| Honors College | \$3M |
| Lundquist College of Business | \$36M |
| College of Education | \$20M |
| School of Journalism & Communication | \$16M |
| School of Law | \$26M |
| School of Music and Dance | \$14M |

| E&G Revenue Source | FY 2023 |
|-----------------------------------|---------|
| State Appropriations | \$91M |
| Res Undergrad Tuition & Fees | \$85M |
| Non-Res Undergrad Tuition & Fees | \$288.M |
| Institutionally Funded Remissions | \$69M |
| Annual Strategic Investment Fund | \$2M |

Annual Operating Costs

Annual Costs – First Year in Operation

| Annual Costs in 2028 | BAU | BAU w/ CPP | Option 2a | Option 2b |
|----------------------|--------------|--------------|--------------|--------------|
| 2028 Nominal Value | \$23,200,000 | \$23,500,000 | \$32,700,000 | \$28,400,000 |
| Marginal cost vs BAU | | \$300,000 | \$9,500,000 | \$5,200,000 |
| Present Value | \$20,000,000 | \$20,300,000 | \$28,200,000 | \$24,500,000 |
| Marginal cost vs BAU | | \$300,000 | \$8,200,000 | \$4,500,000 |

- 2027 is anticipated first year in operation for the electric boilers but had large maintenance cost across all options
- Operating annual cost premium for options 2a and 2b due to electricity costs

| Annual Costs in 2038 | BAU | BAU w/ CPP | Option 3 | Option 4 |
|----------------------|--------------|--------------|---------------|---------------|
| 2038 Nominal Value | \$42,800,000 | \$43,900,000 | \$103,300,000 | \$108,800,000 |
| Marginal cost vs BAU | | \$1,100,000 | \$60,500,000 | \$66,000,000 |
| Present Value | \$27,500,000 | \$28,200,000 | \$66,300,000 | \$69,900,000 |
| Marginal cost vs BAU | | \$700,000 | \$38,800,000 | \$42,400,000 |

- 2038 is first year in full operation for options 3 and 4
- Significant annual cost premium for both options 3 and 4 due to debt service on capital



Key Takeaways



Key Takeaways

- Significant and immediate emissions reductions with Options 2A, 2B but not with Options 3 and 4 (vs BAU)

| Annual Emissions Reduction (vs BAU) | Option 2a (18MW Ele Blr) | Option 2b (8MW Ele Blr) | Option 3 (HPC) | Option 4 (Geo) |
|-------------------------------------|--------------------------|-------------------------|----------------|----------------|
| Annual Emissions Reduction in 2028 | 78% | 45% | 26% | 29% |
| Annual Emissions Reduction in 2033 | 77% | 44% | 41% | 56% |
| Annual Emissions Reduction in 2043 | 76% | 42% | 56% | 76% |
| Annual Emissions Reduction in 2053 | 75% | 42% | 58% | 75% |
| Annual Emissions Reduction in 2085 | 75% | 42% | 58% | 75% |

- Significantly larger construction cost and campus disruption associated with Options 3 and 4

| Construction Costs | Option 2a (18MW Ele Blr) | Option 2b (8MW Ele Blr) | Option 3 (HPC) | Option 4 (Geo) |
|----------------------------------|--------------------------|-------------------------|----------------|------------------------|
| Estimated Project Cost (2023 \$) | \$29,700,000 | \$14,900,000 | \$673,000,000 | \$742,800,000 |
| Potential IRA Credit | \$0 | \$0 | (\$3,400,000) | (\$27.6M) - (\$138.9M) |

- Timeline to implementation for Options 2A/2B is much quicker than Options 3 and 4
 - Options 2A / 2B can be completed in 3 to 5 years
 - Options 3 / 4: 12 years to implementation (if no unforeseen conditions / issues exist)
- Annual operating cost increases vary greatly depending on the option

| Annual Operating Costs Above BAU (NPV) First Year All Systems Operations | Option 2a (18MW Ele Blr) | Option 2b (8MW Ele Blr) | Option 3 (HPC) | Option 4 (Geo) |
|--|--------------------------|-------------------------|----------------|----------------|
| 2038 Marginal Cost (NPV) | \$8.1M | \$4.4M | \$38.9M | \$42.4M |



Evaluation Principles



Evaluation Principles

- Reduction of greenhouse gas emissions
- Consideration of technical feasibility risk
- Resiliency of campus heat production to energy markets and natural hazards
- Impact on the campus experience
- Maintaining appropriate fiscal stewardship



Initial Recommendation



Taskforce Assumptions

1. ***BAU is not acceptable going forward.***
2. ***The electrical grid is less GHG intensive than the natural gas pipeline*** and the taskforce believes is inherently more conducive to GHG reductions over time.
3. ***Time is of the essence***, and moving forward with decarbonization efforts which reduce GHG emissions in the short-term is critical to be directionally consistent with the science of climate change. Carbon emissions reductions now are more important than decarbonization efforts later.
4. Regulatory uncertainty around Oregon's CPP will continue for at least the next few years as Oregon DEQ, natural gas providers and the courts work through legal issues. Improvements through ***the CPP could be useful adjuncts to whatever plan the UO moves forward with but should not be the basis of our GHG reduction efforts.***

Initial Taskforce Recommendation

1. The university should ***move forward with Option 2B*** as it provides for significant and immediate emissions reductions (up to 45% annually) and is a ***partner technology*** to Option 3, Option 4 and could be the first step towards Option 2A or to additional/new heating technology as it develops.

Option 2B is not sufficient on its own over the long-term and is a first step.

2. The university should make a ***clear and public commitment including timelines*** and charging an office, likely the Office of Sustainability ***through the Climate Action Plan 3*** (to be approved in Spring 2024) to complete the following additional analysis:

- Refinements to and/or next steps associated with Option 2B such as ***battery or thermal storage systems*** which could further increase system efficiency and reduce campus GHG emissions.
- ***Technological and regulatory developments*** that may further alter the GHG emissions and economic realities of the options evaluated by the Taskforce or others unforeseen today that could trigger additional investment.

Discussion of Other Options

Option 2A:

Moving forward with Option 2A fully commits the university to a relatively old technology that is expensive to operate, may become a “stranded asset” and does not use electricity as efficiently as possible. This could be a future option if other technology does not develop but is not advisable at this time.

Option 3 /4:

Moving forward with the steam to hot-water construction project and associated building conversions, does not make sense at this time because;

- Equal or greater GHG reductions are available with Options 2A or 2B
- The long phase-in period (12+ years) will not deliver meaningful emissions reductions for a protracted period of time
- The extremely high cost in both relative and absolute terms when compared to either Options 2A and 2B could not be absorbed without significant budget cuts and negative impacts to our teaching, research and public service mission
- The significant activity/incentives around technological innovation in steam production technology because of the IRA and other decarbonization efforts over the coming years may create other more attractive options.

Questions & Feedback

